

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Kraus Floors with More

1551 Chruch Avenue, Winnipeg, MB, Canada

For the following product(s):

Vinyl Tile:

Aspen Peak (Added: 8/5/15), Carlota Plank, Carlota Tile, Culbres, Culbres Tile (Added: 8/5/15), Culbres Calibre Plank (Added: 8/5/15), Culbres Calibre Tile (Added: 8/5/15), Culbres Wide (Added: 8/5/15), Easyfix Plank (Added: 8/5/15), Easyfix Tile (Added: 8/5/15), Lonsdale Plank, Panetola Tile, Robusto Plank, Toscana Plank (Added: 8/5/15), Toscana Tile

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-03135

Valid from: July 15, 2015 to May 31, 2016

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0821



A handwritten signature in blue ink that reads "Robert J. Hrubes".

Robert J. Hrubes, Ph.D., Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA